NATURAL RESOURCES CONSERVATION SERVICE Wvoming CONSTRUCTION SPECIFICATIONS **FOR** WATER WELL

(Owner/Operator)

GENERAL

Installation shall be in accordance with a design and plan approved by the responsible technician. Details of construction shown in the design and plan or described in the State of Wyoming State Engineer's Office "Regulations and In Structures", Part II, Groundwater but not included here shall be considered as a part of this specification. Construction activities shall be in accordance with applicable OSHA regulations.

CASING

Steel Pipe. Steel pipe used for well casing shall meet or exceed the requirements specified in ASTM A 589.

<u>Plastic Pipe</u>. Plastic pipe used for well casing shall conform to ASTM F 480. Plastic casings for transporting potable water supplies shall be NSF approved.

Joint Strength. Well casing joints shall have adequate strength to carry the load due to the casing length and still be watertight, or shall be mechanically supported during installation to maintain joint integrity. Such mechanically supported casings shall terminate on firm material that can adequately support the casing weight.

SCREEN

A well screen shall be installed in any earth material likely to produce silt or sand. Well screens may be constructed of commercially manufactured screen sections, well points, or field-perforated sections. The screen should be constructed with the slot width determined from formation samples.

(Project/Title)

Perforation by any method is allowable provided proper slot size and entrance velocity limits can be met. The length and open area of the screen shall be sized to limit entrance velocity of water into the well to less than or equal to 0.1 foot per second

Depth of the aquifer below ground surface and the thickness of aguifer to be penetrated by the well shall govern the position of the screen in the well.

Maximum drawdown shall not be permitted below the top of the highest screen or pump intake.

Telescoped screen assemblies shall be provided with one or more sand-tight seals between the top of the telescoped screen assembly and casing.

Installation of a filter pack around the well screen shall be considered under the following conditions: presence of a poorly graded, fine sand aquifer; presence of a highly variable aguifer, such as alternating sand and clay layers: presence of a poorly cemented sandstone or similar aquifer; a requirement for maximum yield from a low-yielding aquifer; and holes drilled by reverse circulation.

For heaving or caving sands, silty or finegrained aquifers, and for horizontal or angled wells, a commercial prepacked well screen may be substituted for a conventionally installed (by tremie) filter pack.

INSTALLATION

Borehole. Drilled, jetted, bored, and driven wells shall be sufficiently round, straight, and of adequate diameter, to permit satisfactory installation of inlet, well casing, filter pack, and

annular seal, and passage of tremie pipe (including couplings), if used.

<u>Use of Casing</u>. Casing shall be installed to seal out undesirable surface or shallow ground water and to support the side of the hole through unstable earth materials. The intake portion of a well through stable geologic formations may not require casing. Steel casing shall be used in driven wells.

All wells shall be cased to a sufficient height (minimum of 12 inches) above the ground surface to prevent entry of surface and near-surface water.

Casing for artesian aquifers shall be sealed into overlying, impermeable formations in such a manner as to retain confining pressure.

If a zone is penetrated that is determined or suspected to contain water of quality unsuitable for the intended use, the zone shall be sealed to prevent infiltration of the poor-quality water into the well and the developed portion of the aquifer.

Casing shall extend from above the ground surface down through unstable earth materials to an elevation of at least 2 feet into stable material or to the top of the screen.

<u>Casing Diameter</u>. Casing diameter shall be sized to permit satisfactory installation and efficient operation of the pump, and large enough to assure that uphole velocity is 5 feet per second or less, to protect against excessive head loss.

Well Development. Wells to be completed without a filter pack in unconsolidated granular aquifers shall be developed following guidance provided in ASTM D 5521, Standard Guide for Development of Ground-Water Monitoring Wells in Granular Aquifers. The method shall be selected based on geologic character of the aquifer, type of drilling rig, and type of screen.

Aquifer Development. For massive, unfractured rock formations unresponsive to well development procedures, the use of aquifer stimulation techniques may be considered to improve well efficiency and specific capacity. Techniques may include dry ice, acidizing,

explosives, or hydrofracturing, depending on the composition and structure of the formation.

Grouting and Sealing. The annulus surrounding the permanent well casing at the upper terminus of the well shall be filled with expansive hydraulic cement (ASTM C 845), shrinkage-compensating concrete, bentonite-based grout, clay, or other material with similar sealing properties. The length of the grout seal shall be no less than 10 feet and not less than the minimum specified in state or locally applicable construction codes.

If the water is intended for human consumption, the casing shall be surrounded at the ground surface by a 4-inch thick concrete slab extending at least 2 feet in all directions.

A positive seal (grouted in place) or packer shall be provided between the casing and the less pervious material overlying the aquifer of artesian wells, and in all aquifers where comingling of waters is undesirable.

Access Port. An access port with a minimum diameter of 0.5 inch shall be installed to allow for unobstructed measurement of depth of the water surface, or for a pressure gage for measuring shut-in pressure of a flowing well. Access ports and pressure gages or other openings in the cover shall be sealed or capped to prevent entrance of surface water or foreign material into the well. Removable caps are acceptable as access ports.

<u>Disinfection</u>. Wells shall be disinfected immediately following their construction or repair to neutralize any contamination from equipment, material, or surface drainage introduced during construction. The disinfection process shall comply with all local or state requirements.

Water Quality Testing. Sampling and testing shall comply with all applicable federal, state, and local requirements associated with the intended use(s) of the water.

ADDITIONAL SPECIFICATIONS